

Dylan,

Right away I have concerns for fire department access on all 3 of these buildings. In accordance with 527 CMR chapter 18 new construction must provide 20' wide fire department access roads to the buildings which is hampered in many places by vehicle parking on the proposed plans.

**Deputy Chief Rob Crabtree** | *Division Head*

Fire Prevention Bureau

City of Lowell Fire Department

341 Pine St | Lowell, MA 01852

t: 978.674.4594 | f: 978.970.4140 | [www.Lowellma.gov](http://www.Lowellma.gov)

**LOWELL** *Alive. Unique. Inspiring*